



# Grants Pass Water Lab

"Fast & Reliable Water Testing Since 1978"

964 SE M Street · Grants Pass, OR 97526 · 541-476-0733 · [www.gpwaterlab.com](http://www.gpwaterlab.com) · ORELAP# OR100033

**Mail To:**

Attn: Lake County ESD  
357 N L St  
Lakeview, OR 97630

Date: May 22, 2026  
Address of Source: 357 N L St  
Sample ID #: 22601604  
Project Name: Lake County ESD

## Analysis Report

The following results pertain only to the samples submitted, and are for the sole and exclusive use of the above named client.

This report shall not be reproduced, except in full, without written approval of the laboratory.

The following accredited results meet all requirements of ISO/IEC17025:2005 unless otherwise noted by data flag indicators or comments.

The color coded key is only a guide for interpreting results. All evaluations should be compared to the limitations set by the EPA and/or your primary care physician.

Please do not hesitate to call to discuss results or ask any questions. We are at your service!

Sincerely,

Doree Schaafsma  
Laboratory Director

## Sample Information

Sample ID:	22601604	Collectors Name:	GPWL
Address of Source:	357 N L St	Sample Point:	N/A
Project Name:	Lake County ESD	Source:	N/A
Received Date:	05/18/2026	Treatment System:	None

## Results of Chemical Analysis

Sample Notes: <b>Mens Bathroom</b>		Collection Date: <b>05/18/26 10:25 AM</b>								
Contaminant	Method	LOQ	RESULTS	Units	EPA Limit	Date Analyzed	Analyst	ID	Data Flags	
Lead	SM 3113 B	0.005	0.0085	mg/L	0.015	05/20/26 2:07 pm	PVS	AA	A	
Sample Notes: <b>Womens Bathroom</b>		Collection Date: <b>05/18/26 10:30 AM</b>								
Contaminant	Method	LOQ	RESULTS	Units	EPA Limit	Date Analyzed	Analyst	ID	Data Flags	
Lead	SM 3113 B	0.005	ND	mg/L	0.015	05/20/26 2:07 pm	PVS	AB	A	
Sample Notes: <b>Utility Sink</b>		Collection Date: <b>05/18/26 10:35 AM</b>								
Contaminant	Method	LOQ	RESULTS	Units	EPA Limit	Date Analyzed	Analyst	ID	Data Flags	
Lead	SM 3113 B	0.005	0.0087	mg/L	0.015	05/20/26 2:07 pm	PVS	AC	A	

**DEFINITIONS AND DATA FLAGS**

A Analysis is covered under ORELAP scope of Accreditation AA Analysis is covered under ISO scope of Accreditation C Sample did not meet acceptance criteria H Analysis performed outside method hold time ID Subsample identifier for each Sample number M Matrix Spike recovery is out of control limits due to matrix interference The LCS was in acceptance limits showing the analysis is in control and the data is acceptable	E Estimated Value LOQ Reporting Limit N/A Not Applicable ND None Detected S Sample Outsourced
---	---

Results Color Key
White - No EPA Limit
Low Risk within EPA Limit
Medium Risk
High Risk Exceeds EPA Limit
Call the Lab to Discuss