

**Lake County ESD  
Radon Test Results  
As of November, 2020**

Kit Number	Start Date	Start Time	End Date	End Time	Facility	Room	Results *	Variance	Analysis Date	%Moisture
7301310	2020-11-25	1:00 pm	2020-11-27	2:00 pm	Lake ESD	EI/ECSE	1.30	0.5	2020-12-02	3.6
7301311	2020-11-25	1:00 pm	2020-11-27	2:00 pm	Lake ESD	ADEL CLERK	1.40	0.4	2020-12-02	4.3
7301312	2020-11-25	1:00 pm	2020-11-27	2:00 pm	Lake ESD	TAC	2.10	0.5	2020-12-02	3.6
7301313	2020-11-25	1:00 pm	2020-11-27	2:00 pm	Lake ESD	FT ROCK	1.60	0.4	2020-12-02	4.5
7301314	2020-11-25	1:00 pm	2020-11-27	2:00 pm	Lake ESD	KELLY CREEK	2.00	0.5	2020-12-02	4.4
7301315	2020-11-25	1:00 pm	2020-11-27	2:00 pm	Lake ESD	KITCHEN	1.90	0.5	2020-12-02	4.4
7301316	2020-11-25	1:00 pm	2020-11-27	2:00 pm	Lake ESD	COGSWELL	1.40	0.5	2020-12-02	4.4
7301317	2020-11-25	1:00 pm	2020-11-27	2:00 pm	Lake ESD	SUPT	1.70	0.5	2020-12-02	4.4
7301318	2020-11-25	1:00 pm	2020-11-27	2:00 pm	Lake ESD	RECEPTION	1.40	0.5	2020-12-02	3.6
7301319	2020-11-25	1:00 pm	2020-11-27	2:00 pm	Lake ESD	BUSINESS MANAGER	1.20	0.5	2020-12-02	3.6
7301320	2020-11-25	1:00 pm	2020-11-27	2:00 pm	Lake ESD	SPEECH	1.10	0.5	2020-12-02	3.6
7301321	2020-11-25	1:00 pm	2020-11-27	2:00 pm	Lake ESD	OFFICE MANAGER	1.10	0.4	2020-12-02	4.4
7301322	2020-11-25	1:00 pm	2020-11-27	2:00 pm	Lake ESD	SPECIAL ED	1.00	0.4	2020-12-02	4.4
7301323	2020-11-25	1:00 pm	2020-11-27	2:00 pm	Lake ESD	CUBBY	1.00	0.4	2020-12-02	4.4
7301324	2020-11-25	1:00 pm	2020-11-27	2:00 pm	Lake ESD	COPY ROOM	1.40	0.4	2020-12-02	4.4
7301325	2020-11-25	1:00 pm	2020-11-27	2:00 pm	Lake ESD	WORK ROOM	1.10	0.4	2020-12-02	4.3

\* Results are presented in pCi/L measurements (i.e. EI/ECSE office has a radon level of 1.30 pCi/L)

\*\* According to the EPA, the maximum "acceptable" level of radon is 4.0 pCi/L.